

(a) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2018-01-11	TECHNICIAN Darren Mann		JOB/ORDER # 8095		REFERENCE TEXT Client reference
FIRST NAME Dunowen Properties		LAST NAME Admin	7		
BILLING ADDRESS DUNOWEN PROPERTIES 201 - 1288 ALBERNI STREET VANCOUVER, V6E 4N5 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1602 - 1200 ALBERNI ST VANCOUVER, BRITISH COLUMBIA, CANADA	
PHONE 604.736.1900				EMAIL operations@dunowen.com	

REASON FOR TODAY'S CALL: Issues with toilets

DESCRIPTION OF WORK PERFORMED:

?Guest Bathroom: The flapper was warped. I replaced the flapper and tested. ?Master Bathroom: The Lever handle was sticking in the open position, the chain on the flapper was too long, and the fillvalve was taking a very long time to fill up the tank. I used WD40 to loosen the stiff handle, cut the flapper chain to the correct length, and replaced the fillvalve & supply line. Tested and in good working order.

QTY.	CODE			DESCRIPTION	UNIT PRICE	PRICE	
1		Replace Toilet FillV	ace Toilet FillValve, Flapper, Supply - Standard				\$169.00
Cure of Goodle al			WARRANTY:	PARTS - SUBJECT TO MANUFACTURER'S WARRANTY LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 3 MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE WARRANTY ON CUSTOMER SUPPLIED MATERIALS. THE LEGAL RATE IS CHARGED ON PAST DUE ACCOUNTS, ACKNOWLEDG		SUBTOTAL:	\$169.00
Guve us Geedback Please visit our feedback page at: <u>www.yaletownplumbing.com/feedback</u> [1] Fill in the required details from your invoice and tell us how we did. <u>Thank You!</u>					GST (5%):	\$8.45	
					TOTAL:	\$177.45	
		SETTLED, RU RESULTING	LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT USTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OL FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPIN "CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, I E. & O. E. CUSTOMER SIGNATURE	JTS AND ANY OTHER DAMAGES G.			
				CUSTOMER SIGNATURE	DATE		