

(a) @SimplyPlumbing f YaletownPlumbing

HST #837181627

DATE 2018-03-08	TECHNICIAN Darren Mann		JOB/ORDER # 8251		REFERENCE TEXT Client reference
FIRST NAME Linda		LAST NAME Ou	7		
BILLING ADDRESS COMPANY / BILLING NAME 1904 - 1055 HOMER ST VANCOUVER, V6B 1G3 BRITISH COLUMBIA, CANADA			4	SERVICE ADDRESS 1904 - 1055 HOMER ST BUZ#2015 VANCOUVER, V6B 1G3 BRITISH COLUMBIA, CANADA	
PHONE 778.723.8255				EMAIL lindaou02@gmail.com	

REASON FOR TODAY'S CALL:

After I flush, my toilet tank does not fill up and I will hear this leaking sound from the left part of the fill valve.

DESCRIPTION OF WORK PERFORMED:

I replaced the toilet fillvalve & supply line and tested. Toilet flushing normally.

QTY.	CODE		DESCRIPTION	UNIT PRICE	PRICE
1		Replace toilet FillVal	\$159.00	\$159.00	
Give us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback [1] Fill in the required details from your	and a du	ARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$159.00	
		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF MAINTENANCE IS NOT DONE ON NEW UNITS, OR PAYMENT NOT MADE, ABSOLUTELY NO	GST (5%):	\$7.95	
	com/feedback [1]	WARRANTY ON CUSTOMER SUPPLIED MATERIALS.	TOTAL:	\$166.95	
	t tell us how v		MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES AND MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR BROKEN, SETTLED, RUSTED, DETERIORATION, OR LEAD PIPES, FIXTURES, CLEAN OUTS AND ANY OTHER DAMAGES RESULTING FROM CLEANING OR REPAIRING EXISTING FIXTURES OR PIPING. TEMMS: NET CASH THE AMOUNTS CONTAINED HEREIN ARE FOR LABOUR, MATERIALS AND TRUCK CHARGES. E. & O. E. 2018-03-08 CUSTOMER SIGNATURE DATE		