

Phone: 604.727.4484 yaletownplumbing.com

(B) @SimplyPlumbing | | YaletownPlumbing

2018-04-04

HST #837181627

DATE 2018-04-04	TECHNICIAN Darren Mann		JOB/ORDER # 8356	REFERENCE TEXT Client reference
FIRST NAME Nikki		LAST NAME Scarborough		
BILLING ADDRESS COMPANY / BILLING N 902-238 WEST BROAD VANCOUVER, V5Y0L2 BRITISH COLUMBIA, C	WAY		SERVICE ADDRESS 902 - 238 WEST BRIVANCOUVER, V5YO BRITISH COLUMBIA	OADWAY, BUZZER 1912 DL2
PHONE 604-790-1533			EMAIL nikki.scarborough@g	gmail.com

REASON FOR TODAY'S CALL:

hi, I have a air admittance valve off of my kitchen sink and it stinks - when I google it, it says it is to allow air in and should not smell or release air out. Can this be fixed? * My boyfriend Sean will be here. Our buzzer is #1912 and his cell is 604-787-3671.

DESCRIPTION OF WORK PERFORMED:

The original air admittance valve was installed with a fernco clamp around the threads of the valve allowing small amounts of gas seepage. This valve would have come with an adaptor that the installer chose not to use. Unfortunately I did not have a fitting that would adapt this original valve to the vent piping. I replaced the valve with a new air admittance valve.

QTY.	CODE	DESCRIPTION	UNIT PRICE	PRICE
1		Replace Air Admittance Valve		\$149.00
Q.,,,		WARRANTY: PARTS - SUBJECT TO MANUFACTURER'S WARRANTY	SUBTOTAL:	\$149.00
Gwe us Feedback Please visit our feedback page at: www.yaletownplumbing.com/feedback Fill in the required details from your invoice and tell us how we did. Thank You!		LABOUR - 1 YEAR ON NEW UNITS, 30 DAYS ON REPAIR, VOID AFTER 30 DAYS IF		\$7.45
			TOTAL:	\$156.45
		We did. MADE THAT SERVICES LISTED ABOVE ARE SATISFACTORY COMPLETED AND THAT CHARGES A MATERIALS LISTED HEREON ARE CORRECT. YALETOWN PLUMBING IS NOT RESPONSIBLE FOR SETTLED BUTSED DETERIORATION OF LEAD RIDES SUTTIES OF A	ND BROKEN, R DAMAGES	

CUSTOMER SIGNATURE